




Life Cycle Triple Bottom Line Cost Analysis of High Performance Building Investments 2020 Case Studies



1. Elkington, John. 1997. *Cannibals With Forks: Triple Bottom Line of 21st Century Business*.
2. McDonough, William, and Michael Braungart. 2002. "Design for the Triple Top Line: New Tools for Sustainable Commerce." *Corporate Environmental Strategy* 9 (3): 251–258.
3. Eccles, R. G., & Ambrester, K. (2011). Integrated Reporting in the Cloud. *IESE Insight*, (8.1), 13–20.

Life Cycle Costing (LCC) and Triple Bottom Line (TBL)




Incorporating Financial, Natural, and Human Capital in Facility Decision Making

- Method and approach
- Case studies
- Take-aways and report


Facility investment decisions are still grounded in a short term financial bottom line...

Financial Capital



...so the federal government developed standards for calculating the long term financial bottom line

Life Cycle Costing (LCC)



(NIST, 1995, 2003, annual addenda)

LCC estimates the overall costs of project alternatives to select the design with the lowest overall 'cost of ownership' consistent with the facility quality and [function](#). A long list of factors are to be considered, as available:

1. **Initial Costs**—Purchase, Acquisition, Construction Costs
2. **Fuel Costs**
3. **Operation, Maintenance, and Repair Costs**
4. **Replacement Costs**
5. **Residual Values**—Resale or Salvage Values or Disposal Costs
6. **Finance Charges**—Loan Interest Payments
7. **Non-Monetary Benefits or Costs**

LCC = investment cost + maintenance and repair + energy + water + replacement costs – salvage value
Future Values Discounted to Present Value

Other standard methods for calculating financial outcomes

Return on Investment (ROI), Payback, and Net Present Value (NPV)



ROI = Annual Benefits / First Costs

Payback = First Costs / Annual Benefits

NPV = Annual Benefits – Annual Costs


Future Values Discounted to Present Value

Costs can include investment, maintenance, and replacement costs

Benefits can include income, energy related and other benefits


Financial Capital

Present Value Life Cycle Cost




+ Natural Capital

Present Value Life Cycle Cost



+ Human Capital

Present Value Life Cycle Cost



NASA case study Hypothesis 2

Present Value Life Cycle Cost = 30 year study period, 2% discount rate

Ive (2006) Re-examining the costs and value ratios of owning and occupying buildings, Building Research and Information, 34:3, 230-245

Triple Bottom Line Life Cycle Cost elevates the total cost of ownership by deliberately calculating three bottom lines: Financial, Natural and Human Capital Cost and Benefits

The Triple Bottom Line (TBL)

Financial Capital

- energy savings
- real estate space savings
- water savings
- stormwater fee savings
- flexible programming, event support with artifact security (museum specific)
- **Marketing benefits**
- facility management savings
- avoided property damage
- peak power savings
- Real estate value/vacancy
- Tax code/insurance
- Salvage savings

Natural Capital

- carbon savings
(of kWh savings)
- air quality benefits (of kWh)
(PM2.5, SOx, NOx, ozone..)
- water savings
(of kWh savings)
- **avoided regional flooding risk**
- artifact preservation
(museum specific)
- reduced heat island
- reduced energy waste
- reduced material resource use

Human Capital

- productivity
- visitor/customer numbers
- visitor length of stay, fatigue
- educational value
- absenteeism
- presenteeism
- task/cognitive performance
- health: colds, flus, headaches, skin, eye, musculo-skeletal, stress, digestive, endocrine,
- occupant comfort and satisfaction
- customer satisfaction

TBL / LCC Methodology



Develop Hypotheses

- identify high performance components and / or systems



Establish Cost Differentials

- track cost differentials for high performance components and systems (paying for performance)



Identify Benefits

- identify possible benefits from those systems across financial, environmental and human outcomes



Assign Values through Expert Knowledge and Research

- quantify variables from project data or reputable sources, e.g., \$50 mTCO₂; Value of reduced headaches to employer relative to health care costs and productivity



Calculate Return-on-Investment

- using cost differentials and benefits, calculate annual ROI and payback period



Calculate Lifetime NPV and LCC

- for NPV and LCC calculation, set a timeline linked to the building life, investment life, or system life




Show all Assumptions

- keep all assumptions obvious (and cited) so they can be modified by the decisionmakers



Make the case!

CII TBL LCC Case studies 2020



The National Museum of African American History & Culture Case Study

Smithsonian Institution



The NMAAHC Case Study: 3 Hypotheses



BOX-IN-A-BOX-IN-A-BOX PLANNING

Each nested zone provides allows for diverse conditioning rules for daylight, temperature and humidity, as well as access.



WATER COLLECTION AND REUSE SYSTEM

Reusing water from rainwater, groundwater, and condensate, with 100,000 gallon holding tank, filtration, and a 15,000-gallon clean water storage tank.



DOAS, HEAT RECOVERY, AND CHILLED BEAM SYSTEM

Highly efficient central plan systems using fan walls, dedicated outside air, and enthalpy recovery as well as chilled beams in offices.

Box in a Box Hypothesis





BOX-IN-A-BOX-IN-A-BOX PLANNING



The investments in the NMAAHC museum's four layered thermal conditioning zones – a box within a box within a box within a box -

1. Airtight, dry exhibit cases (70F, 50% RH), inside
2. Exhibit visitor zone (70-74F, 50%+/- RH), inside
3. Generous, daylit circulation and congregation zone (68-78F, no RH control), inside
4. Shading zone (Corona)


lead to significant triple bottom line benefits (profit, planet, people).




The Corona is an exhibit itself (with retail value), a cultural object, a minority industry, and an energy saver.




Variations in Corona densities manage heat gain and glare




TYPE 1
65% Opacity



TYPE 3
75% Opacity



TYPE 5
85% Opacity



TYPE 6
90% Opacity



The vibrant atrium is a high function space, with dynamic environmental conditions separated from artifacts, with significant cost premiums...



3-D Atrium space cost premiums

31,000 sqft of space given up (7.72% of total area)
at \$1000/ sqft = **\$31 Million**

+ Corona first cost premiums

Corona and Glazing Increase = **\$10 Million**

The exhibit space conditioning and quiet is ensured with automatic glass doors



and the artifacts are protected in airtight desiccant chambers



The first cost of the 'box in a box in a box' solution is substantial...




Triple Bottom Line calculation

Cost of layered thermal conditioning zones in NMAAHC

	Total Amount	Total Cost	\$/ sq. ft.	\$/ visitor
Airtight, dry exhibit cases upcharge (100 cases at \$2,000 each)	100 cases	\$200,000	\$0.49	\$0.1
Automatic doors for exhibit visitor zones (5 doors at \$20,000 each)	5 doors	\$100,000	\$0.24	\$0.05
Large circulation zones and atrium spaces (7.72% at \$1,000/sqft)	31,000 sqft	\$31,000,000	\$75.61	\$14.76
Cost of 77% glass vs 40% glass + Cost of Corona		\$10,000,000	\$24.39	\$4.76
Increased Investment for NMAAHC		\$ 41,300,000	\$100.7	\$19.67



Increased first cost \$41,300,000 or \$100/sqft

Total Building Square Footage: 410,000
Averaged annual visitor number: 2,100,000



*Yet the benefits of the nested zones
are even more striking:*

Visitor numbers
Visitor length of stay
Energy savings
Artifact preservation
Event destination
Retail sales



Triple Bottom Line

The investments in the NMAAHC museum's four layered thermal conditioning zones – a box within a box within a box within a box



BOX-IN-A-BOX-IN-A-BOX PLANNING

1. Airtight, dry exhibit cases (70F, 50% RH), inside
2. Exhibit visitor zone (70-74F, 50%), inside
3. Generous, daylit circulation and congregation zone (68-78F), inside
4. Shading zone (Corona)

led to the following triple bottom line benefits (profit, planet, people)

Increased Costs

- Airtight, dry exhibit cases vs alternative
- Exhibit visitor zone (70-74F) with automatic doors (vs open galleries)
- **Larger Circulation zone (68-78F)** with daylight, places to congregate (% area delta)
- **Shading zone (unconditioned)**; cost of 77% glass vs 40% and cost of Corona (with energy penalty?)

Financial capital benefits

- Conditioning energy savings
- Lighting energy savings
- Facility management savings (stringent conditions confined to smaller areas)
- Flexible programming, event support with artifact security

Natural capital benefits

- Carbon savings based on energy savings
- Artifact preservation and security

Human capital benefits

- Architecture as an exhibit and icon (see gift shop sales and branding)
- Visitor numbers
- Visitor satisfaction
- Visitor length of stay, reduced fatigue



1st Bottom Line for layered thermal conditioning zones Financial Capital savings


	Total Savings Amount	Annual Financial Capital Benefit	\$/ sq. ft.	\$/ Visitor
9% less heating energy (20% of 47% total)	17,396 therms	\$ 21,745	\$0.05	\$0.01
2% less electricity for cooling and ventilation energy	177,956 kWh	\$ 23,134	\$0.06	\$0.01
4% less electricity for lighting energy	355,912 kWh	\$ 46,269	\$ 0.11	\$ 0.02
Facility Management savings (fewer hot-cold-stuffy calls)	-	-	-	-
Event Venue with flexible programming (100 events at \$20,000)	100 events	\$ 2,000,000	\$4.88	\$0.95
Annual 1st bottom line savings		\$2,091,147	+\$5.10	+\$1.00
ROI (Financial)		5.1%		
Simple Payback Period		19 years 8 months		
30-year NPV		\$7,795,000		

Increased first cost \$41,300,000 or \$100/sqft
1st BL \$2.1 M with 19.7 years payback

Assumptions:

- NMAAHC heating energy savings are 47% of 109,000 therms of natural gas, of which including 90% for space heating, and 18% of the 7,960,000 kWh of electricity, of which including 50% for cooling and ventilation, 20% for lighting energy. **The layered thermal conditioning setting is contributing 20% of the heating, cooling and ventilation energy savings.**
- The gas price in DC area is around \$1.25/therm, The electricity price has been set at \$0.13/kwh (US Bureau of Labor Statistics, 2020).
- NMAAHC hosted 100 events in 2018, with an overall income of \$2,000,000.

2nd Bottom Line: the carbon, SO_x, NO_x, particulate and water benefits of kWh savings





2nd Bottom Line for layered thermal conditioning zones

Natural Capital savings


	Total Amount savings	Annual Natural Capital Benefit	Per sq. ft.	Per visitor
NMAAHC energy savings	533,868 kWh	-	1.3 kWh	0.25 kWh
	17,396 therms	-	0.04 therms	0.01 therms
Carbon reduction	469 metric tons	\$23,450	\$0.06	\$0.01
Air Quality benefits	-	\$4,773	\$0.01	\$0.00
Artifact preservation and security	-	-	-	-
Annual 2 nd bottom line savings	-	+\$28,223	+\$0.07	+\$0.13
Cumulative ROI (Financial + Natural)			5.1%	
Simple Payback Period			19 years 6 months	
Cumulative 30-year NPV			\$10,999,000	

Increased first cost \$41,300,000 or \$100/sqft
 1st BL \$2.1 M with 19.7 years payback
 + 2nd BL \$28,300 with 19.5 years payback

Assumptions:

- Heating energy savings are 47% of 109,000 therms of natural gas, including 90% for space heating, and 18% of the 7,960,000 kWh of electricity, of which including 50% for cooling and ventilation, 20% for lighting energy. **The layered thermal conditioning setting is contributing 20% of the heating, cooling and ventilation energy savings.**
- Based on the EPA's greenhouse gas equivalencies calculator, these energy savings are equivalent to 469 metric tons of carbon reduction (EPA, 2018).
- \$50/ metric ton of CO2 value; the economic value of the reductions in PM2.5, SOx and NOx, saving the region \$0.00894/kWh, (Srivastava, 2017)


3rd Bottom Line: the doubling of Visitor Length of Stay




Other SI museums

NMAAHC 4-6 hours actual

and increased visitor expenditures in gift shops and food service.



National Average



NMAAHC



3rd Bottom Line – Human Benefits

Possible **explanations for the doubling of the visitor length of stay**



The newest building, hard to get into, and a pilgrimage for many visitors (the newness should have faded by the 3rd year but did not) **(20%)**



The most powerful storyline, carrying you through history of great meaning and diversity, and ‘you want to read to the end’. **(20%)**



The freshest air in a museum, that measurably reduces fatigue. **(15%)**



Thermally, visually, acoustically and spatially dynamic spaces between the hushed, cool galleries (**the box in a box calculation (20%)**), including an entry fountain and contemplation court to regenerate energies (the water calculation **(5%)**).



The best food on the Mall to regenerate energies **(20%)**



3rd Bottom Line for layered thermal conditioning zones

Human Capital savings

	Annual Human Capital Benefit	Persq. ft.	Per visitor
Visitor numbers (10% avoided SI drop * \$13 avg nat. entry*2.1 M visitors * 20% impact)	-	-	-
Visitor Satisfaction and Comfort	-	-	-
Visitor Length of Stay (20%) Reduced fatigue	\$1,820,000	\$4.44	\$0.87
Architecture related retail sales Architecture as exhibit and icon	\$1,396,500	\$3.41	\$0.67
Annual 3rd bottom line savings	\$3,216,500	+\$7.85	+\$1.54
Cumulative ROI (Financial + Natural + Human)		13%	
Simple Payback Period		7 years 8 months	
Cumulative 30-year NPV		\$83,037,000	

Assumptions:

- Average museum expenses per party per trip is \$22 (Vander Steop, 2004)
- Assuming average expenses for NMAAHC is \$35 per party per trip, and 3 people per party. Total visitor length of stay benefits is (\$35- \$22) /3 = \$4.33.
- 20% of the benefits of visitor additional length of stay is contributed by the layered thermal conditioning settings.
- According to Tiffany Springgs, the district manager at Smithsonian Enterprise, the annual architecture related merchandise sales are captured at 19% of the total retail sales of \$3.5 per visitor per year, resulting at \$0.67 per visitor per year, translating into total benefits of \$1,396,500 per year

First cost \$41,300,000 or \$100/sqft
1st BL \$2.1 M with 19.7 years payback
+ 2nd BL \$28,300 with 19.5 years payback
+ 3rd BL \$3.2 M with 7.7 years payback



NMAAHC Box in a Box Hypothesis

BOX-IN-A-BOX-IN-A-
BOX PLANNING

The investments in the NMAAHC museum's four nested thermal conditioning zones – a box within a box within a box within a box -

1. Airtight, dry exhibit cases (70F, 50% RH), inside
2. Exhibit visitor zone (70-74F, 50%+/- RH), inside
3. Generous, daylit circulation and congregation zone (68-78F, no RH control), inside
4. Shading zone (Corona), outside

led to significant triple bottom line benefits (profit, planet, people).

	Added Cost/ Benefit	Cumulative Payback	Cumulative ROI	30-year NPV
Increased cost of nested thermal zones	\$41,300,000	-	-	-
Annual Financial Cost-Benefit	\$2,100,000	19.7 yrs	5.1%	\$7,795,000
Annual Financial + Environmental	\$28,300	19.5 yrs	5.1%	\$10,999,000
Annual Financial + Environmental + Human Cost-Benefit	\$3,200,000	7.7 yrs	13%	\$83,037,000




WATER COLLECTION AND REUSE SYSTEM

The Advanced Water System Hypothesis

The investments in the NMAAHC rainwater system for capture and reuse led to triple bottom line benefits (profit, planet, people)

- 1.Green roofs
- 2.Rainwater capture
- 3.Condensate capture
- 4.Groundwater capture
- 5.Storage
- 6.Processing





The advanced water system costs were non-trivial at \$5,460,000 or \$13/sqft.

The first bottom line benefits were also non-trivial:

*the water conservation and grey water sourcing system in NMAAHC **eliminated 1,186,000 gallons of potable water demand each year**, with additional avoided stormwater fees.*





\$ 1st Bottom Line Financial Capital savings

	Total Savings Amount	Annual Financial Capital Savings	\$/ sq. ft.	\$/ Visitor
Rainwater collection	11,000 gallons/mon	\$ 2,442	\$ 0.01	\$0.00
Groundwater collection	1,000,000 gallons/mon	\$ 222,000	\$ 0.54	\$0.11
Condensate water collection	175,000 gallons/mon	\$38,850	\$ 0.09	\$0.02
Total Water use savings	1,186,000 gallons/mon	\$ 263,292	\$ 0.64	\$0.13
Stormwater Fee Rebate	20% off \$25,128 (IAC)	\$5,026	\$0.01	\$0.00
	55% off \$3,204 (DOEE)	\$ 1,762	\$0.00	\$0.00
Avoid Flooding damage to building	-	-	-	-
Annual cost for maintenance	-	-	-	-
Annual 1st bottom line savings		\$270,079.8	\$0.66	\$0.13
ROI (Financial)		4.95%		
Simple Payback Period		20 years 3 months		
30-year NPV		\$ (4,059,000)		


First cost \$5,460,000 or \$13/sqft
1st BL \$270,000 with 20.2 years payback

Assumptions:

DC water River Smart rebates: [RiverSmart Rewards](https://doee.dc.gov/riversmartrewards): provides a discount of up to 55% off DOEE's Stormwater Fee and up to 20% off DC Water's Clean Rivers Impervious Area Charge. D.C. Gov (2013). RiverSmart Rewards and Clean Rivers IAC Incentive Programs. Retrieved June 2020, from <https://doee.dc.gov/riversmartrewards>

The Natural Capital benefits of the NMAAHC's Advanced Water System include two factors:

the carbon benefits of reduced energy for water treatment and distribution



and the benefit of reducing flooding on the National Mall.

If every building that is added and renovated in this 'zone' had an advanced water system like NMAAHC, the proposed \$360 million pumping station would not be needed.



2nd Bottom Line Natural Capital savings

	Total Amount savings	Per sq. ft.	Per visitor
Environmental benefits from water energy savings	83,613 kWh	0.2 kWh	0.04 kWh
Carbon reduction (4.1 TCO2/million gallons)	\$ 2,918	\$0.01	\$0.00
Natural benefits from reduced flooding risk			
Avoided damage to Capital Mall	\$120,000	\$0.29	\$0.06
Artifact preservation	-	-	-
Additional benefits from green roofs			
Reduced heat island	-	-	-
Annual 2nd bottom line savings	\$122,929	+\$0.30	+\$0.06
Cumulative ROI (Financial + Natural)		7%	
Simple Payback Period		13 year 11 month	
Cumulative 30-year NPV		\$ (433,000)	

First cost \$5,460,000 or \$13/sqft
 1st BL \$270,000 with 20.2 years payback
+ 2nd BL \$123,000 with 13.9 years payback

Assumptions:

- 5875 kWh/million gallons energy are used for supplying and treating water. ¹
- 4.1 Metric ton carbon emission per million-gallon water used. ¹ \$50/ metric ton of CO2 value.
- Costs for alternative flooding control for national mall is \$360 million. ² Assuming lifetime of 100 years, shared by 30 buildings on the Mall and Federal Triangle.

1. Griffiths-Sattenspiel, B., & Wilson, W. (2009). *The Carbon Footprint of Water* [PDF]. Portland: The River Network.

2. Greeley and Hansen LLC. (2011). *Federal Triangle Stormwater Drainage Study* (pp. 109-110, Rep.). Washington D.C.: DC Water.
 doi:https://www.ncpc.gov/docs/Federal_Triangle_Stormwater_Drainage_Study_Jul2011.pdf


and in the 3rd Bottom Line is the 5% impact on visitor length of stay offered by the calming and rejuvenating effects of the water features at the entry queue and Contemplation Court.





Advanced Water Hypothesis

WATER COLLECTION AND REUSE SYSTEM



The investments in the NMAAHC rainwater system for capture and reuse for irrigation, toilet flushing and cooling towers:

1. Green roofs
2. Rainwater capture
3. Condensate capture
4. Groundwater capture
5. Water Storage
6. Water Processing


led to triple bottom line benefits (profit, planet, people)

	Added Cost/ Benefit	Cumulative Payback	Cumulative ROI	30-year NPV
Increased cost of Water System	\$5,460,000	-	-	-
Annual Financial Cost-Benefit	\$270,080	20.2 yrs	4.95%	\$(4,059,000)
Annual Financial + Environmental	\$122,918	13.9 yrs	7%	\$(433,000)
Annual Financial + Environmental + Human Capital Benefit	\$455,000	6.4 yrs	16%	\$9,758,000




DOAS, HEAT RECOVERY,
AND CHILLED BEAM
SYSTEM

The HVAC Story



DOAS & Active Chilled beam



Airside Economizer



DOAS, HEAT RECOVERY,
AND CHILLED BEAM
SYSTEM

Advanced HVAC Hypothesis


The investments in the NMAAHC High Performance HVAC Systems

1. Fanwall Technology
2. Airside Economizer increasing Outside Air
3. Enthalpy Recovery
4. Electronic filtration
5. Waterside Economizer to turn off chillers.
6. Office DOAS (Dedicated Outside Air Delivery)
7. Office Chilled Beams

led to triple bottom line benefits (profit, planet, people)

	Added Cost/ Benefit	Cumulative Payback	Cumulative ROI	30-year NPV (NIST/LCC)
Increased cost of HVAC system	\$5,390,000	-	-	-
One-time HVAC investment Space Cost saving	\$2,158,000			
Annual Financial Cost-Benefit	\$179,516	18 yrs	5.6%	\$3,179,000
Annual Financial + Environmental	\$49,914	14.1yrs	7.1%	\$9,783,000
Annual Financial + Environmental + Human Capital Benefit	\$1,364,000	2 yrs	49%	\$40,331,000

NASA Central Campus Headquarters Building



Kennedy Space Center
Titusville, Florida



KSC Headquarters Case Study: 3 Hypotheses



CONSOLIDATING OLD FACILITIES

Consolidating aging, lower-performing facilities into a high-performance building



HIGH PERFORMANCE BUILDING COMPONENTS

High performance building strategies reduce facility LCC and carbon footprint.



PHOTOVOLTAIC PANELS

PV reduces facility LCC and carbon footprint.

KSC Headquarters Building



Concept

- Consolidate buildings from the 1960's
- Campus concept
- 5.5 acre site

KSC Headquarters

- Seven stories, 200,000 square feet
- 500 NASA civil service and contractor employees
- Shared services and shops

LCC analysis

- 30 year, 2% discount rate

CONSOLIDATING EXISTING FACILITIES



The KDC Consolidation would address

- costly maintenance
- highly inefficient energy systems and buildings
- poor working environments
- inefficient workplace space utilization
- enhance the image of the Center
- reduce the NASA built footprint

The facilities were over 50 years old
or at the end of their life cycle in 2014



Central Instrumentation Facility



Old Headquarters Building



Operation & Support Building I



New Headquarters Building



CONSOLIDATING EXISTING FACILITIES



New Facility first costs

- Design
- Construction
- Demolition
- Activation and Move

One-time transient start-up costs include

- LEED commissioning costs




Total	\$87,006,781
Design	\$2,804,281
Construction	\$71,571,500
Demolition	\$ 6,715,000
Activation & Move	\$4,560,000
Transient Start-Up	\$1,356,000






1st Bottom Line for High Performance Facilities Financial Capital savings and LCC



Energy use in U.S. commercial buildings by major end uses, 2012
trillion British thermal units



Source: U.S. Energy Information Administration, 2012 Commercial Buildings Energy Consumption Survey: Energy Usage Summary, Table 5 (March 2016)



Energy + Operation + Maintenance Savings of High Performance Facilities

Electricity, Natural Gas, and Operation and Maintenance Costs

	KSC HQ	Status Quo
Annual Electricity consumption	3,493,347 kWh	17,334,888 kWh
Cost of Annual Electricity consumption	\$ 279,500	\$ 1,386,791
Annual Natural Gas consumption	-	380,170 Therms
Cost of Natural Gas consumption	-	\$ 416,149
Total Cost (Consumption + Operation + Maintenance)	\$ 1,459,659	\$ 5,272,998
Annual Consumption + Operation + Maintenance benefit	\$ 3,813,339	
Present Value of Consumption + Operation + Maintenance	\$ 53,973,717	\$ 204,488,426



\$ 1st Bottom Line for High Performance Facilities Financial Capital savings and economic measures

	Annual Savings	Annualized Financial Capital Benefit	\$/sq. ft.
Financial Capital	13,841,540 kWh 380,170 Therms	\$ 3,813,339	\$ 19.50
Annualized 1 st bottom line savings		\$ 3,813,339	\$ 19.50
ROI (Financial)	4.4 %		
Payback Period	23 years		
	KSC HQ	Status Quo	
30-Year LCC	\$ 140,980,498	\$ 204,488,426	
Reduction in 30-Year LCC	\$ 63,507,928		

Increased first cost \$87,006,781
1st BL \$2,835,624 with 23 year payback

Assumptions:


- Electricity cost is calculated with US average which is \$/kWh = \$ 0.137 https://www.bls.gov/regions/midwest/data/averageenergyprices_selectedareas_table.htm





2nd Bottom Line for High Performance Facilities

Natural Capital savings

U.S. primary energy consumption
quadrillion British thermal units



Energy-related CO₂ intensities by fuel (1990-2017)
million metric tons per quadrillion British thermal units



"Other" in both the commercial and residential sector includes items such as data servers, medical imaging equipment, ceiling fans, and pool pumps which are categorized as "miscellaneous electric loads" by EIA.

Source: U.S. Energy Information Administration, Annual Energy Outlook 2018 (Washington, DC: U.S. Department of Energy, 2018), <https://www.eia.gov/outlooks/aeo>.



2nd Bottom Line

Environmental Savings of High Performance Facilities

Carbon Emission Costs and Benefits	KSC HQ	Status Quo
Annual Electricity consumption	3,493,347 kWh	17,334,888 kWh
Annual difference	13,841,540 kWh	
Annual Natural Gas consumption	-	380,168 Therms
Annual Carbon emissions	1,696 Tons CO₂	10,640 Tons CO₂
Cost of Annual Carbon emissions	\$ 46,158	\$ 300,215
Present Value of Carbon emissions	\$ 2,905,379	\$ 18,227,047
Annual Carbon Emissions reduction	8,944 Tons CO₂ per year	
Annual Carbon Emissions reduction benefit	\$ 254,057	



2nd Bottom Line for High Performance Facilities

Natural Capital savings

	Savings	Annualized Natural Capital Benefit	\$/sq.ft
Annual Carbon Emissions Related to Electricity and Natural Gas Consumption	8,944 Tons CO ₂	\$ 684,111	\$3.50
Annualized 2 nd bottom line savings		\$ 684,111	\$3.50
Cumulative (Financial + Natural) ROI	4.7 %		
Cumulative Payback Period	21		
	KSC HQ	Status Quo	
Cumulative 30-Year LCC	\$ 143,885,877	\$ 222,715,473	
Cumulative Reduction in 30-Year LCC	\$ 78,829,597		

Increased first cost \$87,006,781

1st BL \$2,835,624 with 23 year payback


+ 2nd BL \$ 3,519,735 = cumulative 21 year payback

Assumptions:

- CO₂ emissions related to electricity consumption is 971 lbs per MWh <https://www.eia.gov/electricity/state/florida/>
- Annual value of CO₂ offset from NISTIR 85-3273-35



3rd Bottom Line for High Performance Facilities **Human Capital savings**





3rd Bottom Line for High Performance Facilities

Human Capital savings

	Savings	Annualized Human Capital Benefit	\$/sq.ft
Improved Productivity	3.5% productivity	\$ 4,813,485	\$ 51.70
Annualized 3 rd bottom line savings		\$ 4,813,485	\$ 51.70
Cumulative ROI (Financial + Natural)	6.1 %		
Cumulative Payback Period	16 years		
	KSC HQ	Status Quo	
Cumulative 30-Year LCC	\$ 954,777,545	\$ 1,062,582,556	
Cumulative Reduction in 30-Year LCC	\$ 107,805,011		

Assumptions:

20% to 50% reduction in sick building syndrome (SBS) symptoms is practical in office buildings.
 SBS productivity impact is suggested 2%
 Productivity gains due to improved IEQ is 0.5%-5%
 Average salary per year of the HQ's employees is estimated \$100,000
 Number of employees are approximately 500.

Increased first cost \$ 87,006,781

1st BL \$ 2,835,624 with 23 year payback

+ 2nd BL \$ 3,519,735 = cumulative 21 year payback

+ 3rd BL \$ 4,813,485 = cumulative 16 year payback



HIGH PERFORMANCE BUILDING COMPONENTS

**High performance building strategies
reduce facility LCC and carbon footprint.**

- Cost variables: envelope (glazing and shading), LED lighting, chilled beam, occupancy sensors, high SRI roof membrane, energy efficient elevator
- Financial benefit variables: reduced energy cost
- Environmental benefit variables: reduced carbon footprint of reduced energy use
- Human benefit variables: reduced absenteeism, improved occupant satisfaction and productivity



Operations Support Building (OSB II)

- Five-story
- 189,000-square-foot building
- consists of approximately 960 office spaces
- a 300-person mission conference center





Triple Bottom Line Life Cycle Cost

The investments in the high-performance building strategies reduce facility LCC and carbon footprint

1. Enclosure (glazing and shading),
2. Lighting system
3. HVAC system

led to the following triple bottom line benefits

Increased Costs

- Glazing: insulated glass curtain wall systems (1-7 floor)
- LED lighting (37% additional cost for LED Light Fixtures in lieu of Fluorescent)
- Chilled beam (409 chilled beams, 2 chilled beam pumps, balance of system)

Financial capital benefits

- Conditioning energy savings
- Lighting energy savings

Natural capital benefits

- Lower carbon footprint
- Carbon savings based on energy savings

Human capital benefits

- Occupant satisfaction
- Improved productivity
- Lower absenteeism
- Improved thermal comfort

Triple Bottom Line Life Cycle Cost





High Performance
Building
Components

The investments in the high-performance building strategies reduce facility LCC and carbon footprint

1. Enclosure (glazing and shading),
2. Lighting system
3. HVAC system
4. Energy efficient systems

led to the following triple bottom line benefits

	Added Cost/ Benefit	Cumulative Payback	Cumulative ROI	30-year NPV
Increased cost of high-performance building components	\$3,359,263	-	-	-
Annual Financial Cost-Benefit	\$46,500	68 yrs	1.5 %	\$(3,129,119)
Annual Financial + Environmental	\$33,000	62 yrs	1.6 %	\$(1,796,976)
Annual Financial + Environmental + Human Cost-Benefit	\$417,000	7 yrs	15%	\$8,281,429





PHOTOVOLTAIC PANELS

*PV reduces facility LCC and carbon footprint
with benefits for air quality*



PHOTOVOLTAIC PANELS



PHOTOVOLTAIC
PANELS

The investments in PV reduces facility LCC and carbon footprint

1. Initial cost of PV system
2. Financial benefit variables: energy cost and savings
3. Environmental benefit variables: reduced carbon footprint

led to the following triple bottom line benefits

	Added Cost/ Benefit	Cumulative Payback	Cumulative ROI	30-year NPV
Increased cost of Photovoltaic System	\$5,867,330	-	-	-
Annual Financial Cost-Benefit	\$175,628	26 yrs	3.8%	\$4,661,000
Annual Financial + Environmental	\$227,281	23 yrs	4.3%	\$5,818,000
Annual Financial + Environmental + Human Cost-Benefit	\$227,281	23 yrs	4.3%	\$5,818,000



NASA Design and Management Team	
Specialty	Name
Primary Contact	Keith Britton, Senior Project Manager
	Nicholas Murdock
	Jennifer Hill
	Jonathan Haling
	Thomas Wilczek
Architect	HuntonBrady Architects
LEED Consultant	Exp U.S. Services, Inc

**Life-Cycle Triple Bottom Line Analysis
is only possible with the expertise and
commitment of the project client,
designers and managers.**

Acknowledgement

We thank all the current or former employees listed here, who had worked on the NMAAHC project enthusiastically, and had provided us generous help and valuable information on the NMAAHC project.

Specialty	Name	Title
Primary Contact	Brenda Sanchez	Architect Design Manager
	Larry Travis	Architect predesign engineer
Facility Management	Thomas Reavey	Energy management group
	Paul Estrada	Facility manager
	Ryan Doyle	Zone manager
Engineer	David Venturoso	Senior Associate at WSP
	Paul Corrado	former Sr VP at WSP
	Jonathan Dickinson	former MEP at WSP
Exhibit & Design	Bryan Sieling	Assistant Director for Exhibition Design and Production
Architect SmithGroup Architect Perkins&Will	Monteil Crawley	Associate Architect at SmithGroup
	Zena Howard	Principal
Customer Service	Sherri Wheeler	director of visitor services
Construction	Jared Oldroyd	vice president at Clark Construction
	Derek Ross	chief of Construction at Smithsonian
	Jessica Hibbert	senior project manager
Construction	Mac Naeemi	Project Executive Clark/Smoot/Consigli
Engineer	Victor Olgyay	Principal for Buildings Rocky Mountain Institute
	Elaine Adams	Sustainability Director
Building Energy & Engineering	David Epley	Associate Director for Data & Benchmarking Division
Smithsonian Enterprise	Deborah Palazzo	VP Museum relations and project management
	Jasmine Utsey	Business Liaison Program Specialist

Life Cycle Costing (LCC) Triple Bottom Line (TBL) Case Studies

National Museum of African American History and Culture
&
NASA Central Campus Headquarters Building



CII Construction
Industry
Institute®

Construction Industry Institute

University of Florida
Carnegie Mellon University



Calculating the full cost of ownership using the breadth and longevity of LCC/TBL methods is key to investing in high performance facilities that deliver robust organizational value.

CII LCC Final Report

LCC/TBL Methodology

Smithsonian NMAAHC Case Study

- Nested Zoning
- Advanced HVAC System
- Advanced Water System

NASA HQ Case Study

- High Performance Building Systems
- Photovoltaic System
- Consolidating Facilities